



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION III
1650 Arch Street
Philadelphia, Pennsylvania 19103-2029

NOTIFICATION OF APPROVAL OF FACILITY RESPONSE PLAN

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

DEC 01 2015

Scott Morlen
Environmental Compliance Coordinator
Yorktown Power Station
1600 Waterview Road
Yorktown, VA 23692

Re: FRP Regional ID #: VA-FRP-035
Plan Review Date: November 16, 2015

Dear Mr. Morlen:

This letter is to notify you that the U.S. Environmental Protection Agency, Region III (EPA) has approved your Facility Response Plan (FRP), dated July 2015, for the facility located at 1600 Waterview Road, Yorktown, VA 23692, because it meets the minimum requirements of 40 C.F.R. § 112.20. Your FRP will be maintained in this office while your Facility is subject to jurisdiction under the regulations and it will be treated in accordance with 40 C.F.R. Part 2, Public Information.

When changes occur at a facility that materially affect a facility's ability to respond to a worst case discharge, the facility owner or operator is required to provide EPA with a copy of the FRP revisions that address these changes, within 60 days of each material change, as cited at 40 C.F.R § 112.20(d)(1). Facility changes that may materially affect the response to a worst case discharge include:

- (i) A change in the facility's configuration that materially alters the information included in the response plan;
- (ii) A change in the type of oil handled, stored, or transferred that materially alters the required response resources;
- (iii) A material change in capabilities of the oil spill removal organization(s) that provide equipment and personnel to respond to discharges of oil;
- (iv) A material change in the facility's spill prevention and response equipment or emergency response procedures; and
- (v) Any other changes that materially affect the implementation of the response plan.




In addition, facilities are required to provide EPA any changes to personnel and telephone lists included in the FRP, and other changes in the oil spill removal organization(s) that do not materially affect a worst case discharge, in accordance with 40 C.F.R. § 112.20(d)(2). Please include the facility ID number referenced above on any FRP revisions and send your revisions to:

**U.S. ENVIRONMENTAL PROTECTION AGENCY
ARLIN GALARZA-HERNANDEZ
SPCC/FRP COORDINATOR
OIL AND PREVENTION BRANCH (3HS61)
1650 ARCH STREET
PHILADELPHIA, PA 19103-2029**

Should you have any questions regarding this matter, please contact Arlín Galarza-Hernández, SPCC/FRP Coordinator, at (215) 814-3223.

Sincerely,

A handwritten signature in black ink that reads "Joan Armstrong". The signature is written in a cursive, flowing style.

Joan Armstrong, Associate Director
Office of Enforcement
Hazardous Site Cleanup Division

cc: Arlín Galarza-Hernández